SIEMENS

Data sheet

3RW3014-1BB14




SIRIUS soft starter S00 6.5 A, 3 kW/400 V, 40 $^\circ\text{C}$ 200-480 V AC, 110-230 V AC/DC Screw terminals


General technical data		
product brand name		SIRIUS
product designation		Soft starter
product feature	_	
 integrated bypass contact system 		Yes
thyristors		Yes
product function		
 intrinsic device protection 		No
 motor overload protection 		No
 evaluation of thermistor motor protection 		No
external reset		No
 adjustable current limitation 		No
• inside-delta circuit		No
product component motor brake output		No
insulation voltage rated value	V	600
degree of pollution		3, acc. to IEC 60947-4-2
blocking voltage of the thyristor maximum	V	1 200
reference code according to EN 61346-2		Q
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750		G
Power Electronics		
operational current		
• at 40 °C rated value	А	6.5
● at 50 °C rated value	А	6
● at 60 °C rated value	А	5.5
yielded mechanical performance for 3-phase motors		
• at 230 V		
- at standard circuit at 40 °C rated value	kW	1.5
• at 400 V		
— at standard circuit at 40 °C rated value	kW	3
yielded mechanical performance [hp] for 3-phase AC motor at 200/208 V at standard circuit at 50 °C rated value	hp	1
operating frequency rated value	Hz	50 60
relative negative tolerance of the operating frequency	%	-10
relative positive tolerance of the operating frequency	%	10
operating voltage at standard circuit rated value	V	200 480
relative negative tolerance of the operating voltage at standard circuit	%	-15
relative positive tolerance of the operating voltage at standard circuit	%	10
minimum load [%]	%	10

	- 0/	445
continuous operating current [% of le] at 40 °C	%	115
power loss [W] at operational current at 40 °C during operation typical	W	0.5
Control circuit/ Control		
type of voltage of the control supply voltage		AC/DC
control supply voltage frequency 1 rated value	Hz	50
control supply voltage frequency 2 rated value	Hz	60
relative negative tolerance of the control supply voltage frequency	%	-10
relative positive tolerance of the control supply voltage frequency	%	10
control supply voltage 1 at AC at 50 Hz	V	110 230
control supply voltage 1 at AC at 60 Hz	V	110 230
relative negative tolerance of the control supply voltage at AC at 50 Hz	%	-15
relative positive tolerance of the control supply voltage at AC at 50 Hz	%	10
relative negative tolerance of the control supply voltage at AC at 60 Hz	%	-15
relative positive tolerance of the control supply voltage at AC at 60 Hz	%	10
control supply voltage 1 at DC	V	110 230
relative negative tolerance of the control supply voltage at DC	%	-20
relative positive tolerance of the control supply voltage at DC	%	20
display version for fault signal		red
Mechanical data		
size of engine control device		S00
width	mm	45
height	mm	95
depth	mm	150
fastening method		screw and snap-on mounting
mounting position		With vertical mounting surface +/-10° rotatable, with vertical
		mounting surface +/- 10° tiltable to the front and back
required spacing with side-by-side mounting		20
• upwards	mm	60
• at the side	mm	15
downwards	mm	40
wire length maximum	m	300
number of poles for main current circuit		3
Connections/ Terminals		
type of electrical connection		
 for main current circuit 		screw-type terminals
for auxiliary and control circuit		screw-type terminals
number of NC contacts for auxiliary contacts		0
number of NO contacts for auxiliary contacts		1
number of CO contacts for auxiliary contacts		0
type of connectable conductor cross-sections for main contacts for box terminal using the front clamping point		
• solid		2x (1 2.5 mm²), 2x (2.5 6 mm²)
 finely stranded with core end processing 		2x (1 2.5 mm²), 2x (2.5 6 mm²)
type of connectable conductor cross-sections for AWG cables for main contacts for box terminal		
using the front clamping point		2x (16 10)
type of connectable conductor cross-sections for auxiliary contacts		
• solid		2x (0.25 2.5 mm²)
 finely stranded with core end processing 		2x (0.25 1.5 mm²)
type of connectable conductor cross-sections for AWG cables		
 for auxiliary contacts 		2x (20 14)
for auxiliary contacts finely stranded with core end processing		2x (20 16)
Ambient conditions		

installation altitude at he	eight above sea leve	1	m	5 000		
environmental category						
 during transport according 	cording to IEC 60721			2K2, 2C1, 2S1,	2M2 (max. fall height 0.3	m)
 during storage according 	ording to IEC 60721				ional condensation), 1C2 get inside the devices), 1	
during operation according to IEC 60721			`	on of ice, no condensation not get into the devices),	// \/ //	
ambient temperature						
during operation		°C	-25 +60	-25 +60		
during storage		°C	-40 +80	-40 +80		
derating temperature		°C	40	40		
protection class IP on the front according to IEC 60529			IP20	IP20		
touch protection on the front according to IEC 60529			finger-safe, for v	vertical contact from the fr	ont	
L/CSA ratings						
yielded mechanical perf	ormance [hp] for 3-p	hase AC motor				
• at 220/230 V						
— at standard ci	rcuit at 50 °C rated va	lue	hp	1		
• at 460/480 V						
	rcuit at 50 °C rated va	lue	hp	3		
contact rating of auxilia			12	B300 / R300		
oprovals Certificates	,	3				
General Product Approv	vol.					
					01	
					51	
EMV		Test Certificate	es oth	ner	51	Environment
	KC	Test Certificate	<u>tific-</u>	ner <u>Miscellaneous</u>	<u>Confirmation</u>	Environment
EMV RCM	KC	Type Test Cert	<u>tific-</u>		Confirmation	Environment
RCM	KC	Type Test Cert	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con-	KC	Type Test Cert	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con- firmations	Starters (STS)	<u>Type Test Cert</u> ates/Test Rep	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con- firmations	Starters (STS) emens.com/cs/ww/en/	<u>Type Test Cert</u> ates/Test Rep	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con- firmations	Starters (STS) emens.com/cs/ww/en/ aging	<u>Type Test Cert</u> <u>ates/Test Rep</u>	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con- firmations	Starters (STS) emens.com/cs/ww/en/ aging emens.com/cs/ww/en/	Type Test Cert ates/Test Rep view/101494917 view/109813875	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con- firmations	Starters (STS) emens.com/cs/ww/en/ aging emens.com/cs/ww/en/ oadcenter (Catalogs,	Type Test Cert ates/Test Rep view/101494917 view/109813875	<u>tific-</u>		Confirmation	Environment
Environment Environmental Con- firmations Urther information Simulation Tool for Soft https://support.industry.sie Information on the pack https://support.industry.sie Information- and Downlo https://www.siemens.com Industry Mall (Online or https://mall.industry.siemen	Starters (STS) emens.com/cs/ww/en/ aging emens.com/cs/ww/en/ oadcenter (Catalogs, /ic10 dering system)	Type Test Cert ates/Test Rep view/101494917 view/109813875 , Brochures,)	tific- sort	Miscellaneous	Confirmation	Environment
Environment Environmental Con- firmations Urther information Simulation Tool for Soft https://support.industry.sie Information- and Downle https://www.siemens.com Industry Mall (Online ord https://wall.industry.siemens.com Industry Mall (Online ord Industry Mall	Starters (STS) emens.com/cs/ww/en/ aging emens.com/cs/ww/en/ oadcenter (Catalogs, /ic10 dering system) ens.com/mall/en/en/Ca	Type Test Cert ates/Test Rep view/101494917 view/109813875 Brochures,)	tific- iort	BB14		Environment
Environment Environmental Con- firmations wither information Simulation Tool for Soft nformation on the pack nformation on the pack nformation- and Downlo https://support.industry.sie nformation- and Downlo https://www.siemens.com ndustry Mall (Online or nttps://mall.industry.siemen	Starters (STS) emens.com/cs/ww/en/ aging emens.com/cs/ww/en/ oadcenter (Catalogs, /ic10 dering system) ens.com/mall/en/en/Ca siemens.com/WW/CA als, Certificates, Cha	Type Test Cert ates/Test Rep view/101494917 view/109813875 Brochures,) atalog/product?mlfb= Xorder/default.aspx' aracteristics, FAQs,	tific- sort	BB14		Environment







last modified:

6/28/2024 🖸

9/21/2024