SIEMENS

Data sheet

6AG1315-2FJ14-2AB0



SIPLUS S7-300 CPU 315F-2PN/DP based on 6ES7315-2FJ14-0AB0 with conformal coating, -25...+60 °C, central processing unit with 512 KB work memory, 1st interface MPI/DP 12 Mbps, 2nd interface Ethernet PROFINET, with 2-port switch, Micro Memory Card required

General information	
based on	6ES7315-2FJ14-0AB0
Product function	
Isochronous mode	Yes; Via PROFIBUS DP or PROFINET interface
Engineering with	
Programming package	STEP 7 V5.5 or higher, Distributed Safety V5.4 SP4
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Repeat rate, min.	1 s
Input current	
Current consumption (rated value)	750 mA
Current consumption (in no-load operation), typ.	150 mA
Inrush current, typ.	4 A
² t	1 A²·s
Power loss	
Power loss, typ.	4.65 W
Memory	
Work memory	
• integrated	512 kbyte
• expandable	No
Load memory	
• Plug-in (MMC)	Yes
• Plug-in (MMC), max.	8 Mbyte
 Data management on MMC (after last programming), min. 	10 a
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
without battery	Yes; Program and data
CPU processing times	
	0.05 µs
for bit operations, typ.	
for bit operations, typ. for word operations, typ.	0.09 µs
	0.09 μs 0.12 μs
for word operations, typ.	
for word operations, typ. for fixed point arithmetic, typ.	0.12 µs

Subject to change without notice © Copyright Siemens

	reduced by the MMC used.
DB	
Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	04 KDYIC
	1 024; Number range: 0 to 7999
 Number, max. Size, max. 	
• Size, max. OB	64 kbyte
	C4 libite
Size, max.	64 kbyte
Number of free cycle OBs	1; OB 1
Number of time alarm OBs	1; OB 10
Number of delay alarm OBs	2; OB 20, 21
Number of cyclic interrupt OBs	4; OB 32, 33, 34, 35
Number of process alarm OBs	1; OB 40
Number of DPV1 alarm OBs	3; OB 55, 56, 57
Number of isochronous mode OBs	1; OB 61
Number of startup OBs	1; OB 100
Number of asynchronous error OBs	6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO)
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
per priority class	16
additional within an error OB	4
Counters, timers and their retentivity	
S7 counter	
Number	256
Retentivity	
— adjustable	Yes
— preset	Z 0 to Z 7
Counting range	
— adjustable	Yes
— lower limit	0
— upper limit	999
IEC counter	
• present	Yes
• Туре	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
Number	256
Retentivity	
— adjustable	Yes
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
● present	Yes
• Туре	SFB
Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte
Flag	
• Size, max.	2 048 byte
Retentivity available	Yes; MB 0 to MB 2 047
Retentivity available	MB 0 to MB 15
Number of clock memories	8; 1 memory byte
Data blocks	
	Yes: via non-retain property on DR
Retentivity adjustable	Yes; via non-retain property on DB Yes
Retentivity preset	100

Local data	
 per priority class, max. 	32 768 byte; Max. 2048 bytes per block
Address area	
I/O address area	
Inputs	2 048 byte
Outputs	2 048 byte
of which distributed	
— Inputs	2 048 byte
— Outputs	2 048 byte
Process image	20100340
Inputs	2 048 byte
Outputs	2 048 byte
Inputs, adjustable	2 048 byte
Outputs, adjustable	2 048 byte
Inputs, default	128 byte
Outputs, default	128 byte
	120 byte
Subprocess images	4. With DDOEINET 10, the length of the user date is limited to 1000 by tee
Number of subprocess images, max.	1; With PROFINET IO, the length of the user data is limited to 1600 bytes
Digital channels	40.004
Inputs	16 384
— of which central	1 024
• Outputs	16 384
— of which central	1 024
Analog channels	
Inputs	1 024
— of which central	256
Outputs	1 024
— of which central	256
Hardware configuration	
Number of expansion units, max.	3
Number of DP masters	
 integrated 	1
• via CP	4
Number of operable FMs and CPs (recommended)	
• FM	8
• CP, PtP	8
• CP, LAN	10
Rack	
Racks, max.	4
 Modules per rack, max. 	8
Time of day	
Clock	
Hardware clock (real-time)	Yes
• retentive and synchronizable	Yes
Backup time	6 wk; At 40 °C ambient temperature
 Deviation per day, max. 	10 s; Typ.: 2 s
Behavior of the clock following POWER-ON	Clock continues running after POWER OFF
 Behavior of the clock following expiry of backup period 	the clock continues at the time of day it had when power was switched off
Operating hours counter	
• Number	1
Number/Number range	0
Range of values	0 to 2^31 hours (when using SFC 101)
• Granularity	1 h
retentive	Yes; Must be restarted at each restart
Clock synchronization	
• supported	Yes
• to MPI, master	Yes
	100
	Ves
• on MPI, device	Yes Ves: With DR slave only slave clock
	Yes Yes; With DP slave only slave clock Yes

• in AS, master	Yes
• in AS, device	Yes
on Ethernet via NTP	Yes; As client
Digital inputs	
Number of digital inputs	0
Digital outputs	
Number of digital outputs	0
Analog inputs	
Number of analog inputs	0
Analog outputs	
Number of analog outputs	0
Interfaces	
Number of industrial Ethernet interfaces	1
Number of PROFINET interfaces	1
Number of RS 485 interfaces	1
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Isolated	Yes
Interface types	
• RS 485	Yes
 Output current of the interface, max. 	200 mA
Protocols	
• MPI	Yes
PROFIBUS DP master	Yes
PROFIBUS DP device	Yes
 Point-to-point connection 	No
MPI	
Transmission rate, max.	12 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	Yes
— S7 basic communication	Yes
— S7 communication	Yes
- S7 communication, as client	No; but via CP and loadable FB
— S7 communication, as server	Yes
PROFIBUS DP master	
Transmission rate, max.	12 Mbit/s
 max. number of DP devices 	124
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes
- S7 communication, as client	No
- S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
- SYNC/FREEZE	Yes
 activation/deactivation of DP devices 	Yes
 max. number of DP devices that can be activated/deactivated at the same time 	8
 — Direct data exchange (slave-to-slave communication) 	Yes; as subscriber
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte

1et interface / DD master / navload data nor DD Davies / hand	
1st interface / DP master / payload data per DP Device / head	244 byte
— Inputs, max. — Outputs, max.	244 byte
PROFIBUS DP slave	244 byte
Transmission rate, max.	12 Mbit/s
automatic baud rate search	Yes; only with passive interface
Address area, max.	32
 User data per address area, max. 	32 byte
Services	52 5910
— PG/OP communication	Yes
- Routing	Yes; Only with active interface
Global data communication	No
— S7 basic communication	No
— S7 communication	Yes
- S7 communication, as client	No
— S7 communication, as server	Yes; Connection configured on one side only
— Direct data exchange (slave-to-slave	Yes
communication)	
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
Interface type	PROFINET
Isolated	Yes
automatic detection of transmission rate	Yes; 10/100 Mbit/s
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes
Interface types	
RJ 45 (Ethernet)	Yes
Number of ports	2
integrated switch	Yes
Protocols	
• MPI	No
PROFINET IO Controller	Yes; Also simultaneously with IO-Device functionality
PROFINET IO Device	Yes; Also simultaneously with IO Controller functionality
PROFINET CBA	Yes
PROFIBUS DP master	No
PROFIBUS DP device	No
Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
Web server	Yes; only read function
Media redundancy	Yes
PROFINET IO Controller	
Transmission rate, max.	100 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; With loadable FBs, max. configurable connections: 14, max. number of instances: 32
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
— IRT	Yes
- Shared device	Yes
— Prioritized startup	Yes
- Number of IO devices with prioritized startup, max.	32
- Number of connectable IO Devices, max.	128
- Of which IO devices with IRT, max.	64
— of which in line, max.	64
 — Number of IO Devices with IRT and the option "high flexibility" 	128
— of which in line, max.	61

 — Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Activation/deactivation of IO Devices 	Yes
 — Number of IO Devices that can be simultaneously activated/deactivated, max. 	8
 — IO Devices changing during operation (partner ports), supported 	Yes
 — Number of IO Devices per tool, max. 	8
 Device replacement without swap medium 	Yes
— Send cycles	250 μs, 500 μs,1 ms; 2 ms, 4 ms (not in the case of IRT with "high flexibility"
	option)
— Updating time	250 μs to 512 ms (depending on the operating mode, see Manual "S7-300 CPU 31xC and CPU 31x, technical Data" for more details)
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
— User data consistency, max.	1 024 byte
PROFINET IO Device	
Services	
— PG/OP communication	Yes
- Routing	Yes
— S7 communication	Yes; With loadable FBs, max. configurable connections: 14, max. number of
or communication	instances: 32
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	Yes; With SFB 73 / 74 prepared for loadable PROFlenergy standard FB for I- Device
— Shared device	Yes
— Number of IO Controllers with shared device, max.	2
Transfer memory	
— Inputs, max.	1 440 byte; Per IO Controller with shared device
•	
— Outputs, max.	1 440 byte; Per IO Controller with shared device
Submodules	
— Number, max.	64
— User data per submodule, max.	1 024 byte
PROFINET CBA	
acyclic transmission	Yes
cyclic transmission	Yes
Open IE communication	
 Number of connections, max. 	8
Local port numbers used at the system end	0, 20, 21, 25, 80, 102, 135, 161, 8080, 34962, 34963, 34964, 65532, 65533, 65534, 65535
 Keep-alive function, supported 	Yes
Protocols	
PROFIsafe	Yes
Redundancy mode	
Media redundancy	
— Switchover time on line break, typ.	200 ms; PROFINET MRP
- Number of stations in the ring, max.	50
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
- Number of connections, max.	8
 — Data length for connection type 01H, max. 	1 460 byte
 Data length for connection type 11H, max. 	32 768 byte
— several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes; via integrated PROFINET interface and loadable FBs
 Number of connections, max. 	8
— Data length, max.	32 768 byte
• UDP	Yes; via integrated PROFINET interface and loadable FBs
 Number of connections, max. 	8
— Data length, max.	1 472 byte
Web server	
supported	Yes; only read function
· · ·	

User-defined websites	Yes
Number of HTTP clients	5
communication functions / header	
PG/OP communication	Yes
Data record routing	Yes
Global data communication	100
supported	Yes
Number of GD loops, max.	8
Number of GD packets, max.	8
Number of GD packets, transmitter, max.	8
Number of GD packets, receiver, max.	8
Size of GD packets, max.	22 byte
 Size of GD packet (of which consistent), max. 	22 byte
S7 basic communication	
supported	Yes
• User data per job, max.	76 byte
• User data per job (of which consistent), max.	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET
	as server)
S7 communication	
supported	Yes
• as server	Yes
• as client	Yes; via integrated PROFINET interface and loadable FB or via CP and loadable FB
• User data per job, max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
S5 compatible communication	
supported	Yes; via CP and loadable FC
communication functions / PROFINET CBA (with set target commu	· · · · · · · · · · · · · · · · · · ·
 Setpoint for the CPU communication load 	50 %
Number of remote interconnection partners	32
number of master/device functions	30
 total of all master/device connections 	1 000
 data length of all incoming master/device connections, max. 	4 000 byte
 data length of all outgoing master/device connections, max. 	4 000 byte
 Number of device-internal and PROFIBUS interconnections 	500
 Data length of device-internal und PROFIBUS interconnections, max. 	4 000 byte
Data length per connection, max.	1 400 byte
performance data / PROFINET CBA / remote interconnection	
— Sampling interval, min.	500 ms
 Number of incoming interconnections 	100
— Number of outgoing interconnections	100
— Data length of all incoming interconnections, max.	2 000 byte
 Data length of all outgoing interconnections, max. 	2 000 byte
 data volume / as user data for remote interconnections / in the case of acyclic transmission / with PROFINET CBA / per connection / maximum 	1 400 byte
performance data / PROFINET CBA / remote interconnection	/ with cyclic transfer / header
— Transmission frequency: Transmission interval, min.	10 ms
- Number of incoming interconnections	200
 Number of outgoing interconnections 	200
 — Data length of all incoming interconnections, max. 	2 000 byte
— Data length of all outgoing interconnections, max.	2 000 byte
— data volume / as user data for remote interconnections / with cyclical transfer / with PROFINET CBA / per connection / maximum	450 byte
performance data / PROFINET CBA / HMI variables via PROF	INET / acyclic / header
— Number of stations that can log on for HMI variables (PN OPC/iMap)	3; 2x PN OPC/1x iMap
— HMI variable updating	500 ms
— Number of HMI variables	200

 Data length of all HMI variables, max. 	2 000 byte
performance data / PROFINET CBA / PROFIBUS proxy funct	
— supported	Yes
- Number of linked PROFIBUS devices	16
— Data length per connection, max.	240 byte; Slave-dependent
Number of connections	
overall	16
usable for PG communication	15
- reserved for PG communication	1
 — adjustable for PG communication, min. 	1
 — adjustable for PG communication, max. 	15
usable for OP communication	15
- reserved for OP communication	1
 adjustable for OP communication, min. 	1
 adjustable for OP communication, max. 	15
 usable for S7 basic communication 	14
- reserved for S7 basic communication	0
— adjustable for S7 basic communication, min.	0
- adjustable for S7 basic communication, max.	14
usable for S7 communication	14
- reserved for S7 communication	0
- adjustable for S7 communication, min.	0
— adjustable for S7 communication, max.	14
 total number of instances, max. 	32
usable for routing	X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max.
07	14; X2 as PROFINET: 24 max.
S7 message functions	16: Depending on the configured compactions for DOVOD and 07 basis
Number of login stations for message functions, max.	16; Depending on the configured connections for PG/OP and S7 basic communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300
Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
	Yes; Up to 2 simultaneously Yes
Status block	
Status block Single step	Yes
Status block Single step Number of breakpoints	Yes
Status block Single step Number of breakpoints Status/control	Yes 4
Status block Single step Number of breakpoints Status/control • Status/control variable	Yes 4 Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. — of which control variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof • Number of entries readable in RUN, max.	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499 Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Porcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof • Number of entries readable in RUN, max. — adjustable — preset	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. - of which status variables, max. - of which control variables, max. - of which control variables, max. - of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. - adjustable - of which powerfail-proof • Number of entries readable in RUN, max. - adjustable - preset Service data	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499 Yes 10
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. - of which status variables, max. - of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. - adjustable - of which powerfail-proof • Number of entries readable in RUN, max. - adjustable - preset Service data • can be read out	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499 Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. - of which status variables, max. - of which control variables, max. - of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. - adjustable - of which powerfail-proof • Number of entries readable in RUN, max. - adjustable - preset Service data • can be read out Standards, approvals, certificates	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499 Yes 10
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. - of which status variables, max. - of which control variables, max. - of which control variables, max. - of which control variables, max. Forcing • Present • Number of entries, max. - adjustable - of which powerfail-proof • Number of entries readable in RUN, max. - adjustable - preset Service data • can be read out Standards, approvals, certificates	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499 Yes 10
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof • Number of entries readable in RUN, max. — adjustable — preset Service data • can be read out Standards, approvals, certificates CE mark UL approval	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 30 14 Yes Inputs, outputs 10 Yes 10 Yes 10 Yes Yes; File E239877
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. - of which status variables, max. - of which control variables, max. - of which control variables, max. - of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. - adjustable - of which powerfail-proof • Number of entries readable in RUN, max. - adjustable - preset Service data • can be read out Standards, approvals, certificates CE mark UL approval RCM (formerly C-TICK)	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 30 14 Yes Inputs, outputs 10 Yes 500 No 100 499 Yes 10 Yes Yes
Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present • Number of entries, max. — adjustable — of which powerfail-proof • Number of entries readable in RUN, max. — adjustable — preset Service data • can be read out Standards, approvals, certificates CE mark UL approval	Yes 4 Yes Inputs, outputs, memory bits, DB, times, counters 30 30 30 14 Yes Inputs, outputs 10 Yes 10 Yes 10 Yes Yes; File E239877

Use in hazardous areas	
ATEX	Yes
Marine approval	
American Bureau of Shipping (ABS)	Yes
mbient conditions	
Ambient temperature during operation	
• min.	-25 °C; = Tmin
• max.	60 °C; = Tmax
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	2 000 m
 Ambient air temperature-barometric pressure-altitude 	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m)
Relative humidity	
With condensation, tested in accordance with IEC 60068- 2-38, max.	100 %; RH incl. condensation/frost (no commissioning under condensation conditions)
Resistance	
Use in stationary industrial systems	
— to biologically active substances according to EN 60721-3-3	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
— to chemically active substances according to EN 60721-3-3	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
— to mechanically active substances according to EN 60721-3-3	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	Varia Class CD0 mold and formal ansatz (molecting for a local second
— to biologically active substances according to EN 60721-3-6	Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on request
— to chemically active substances according to EN 60721-3-6	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
 — to mechanically active substances according to EN 60721-3-6 	Yes; Class 6S3 incl. sand, dust; *
Usage in industrial process technology	
 Against chemically active substances acc. to EN 60654-4 	Yes; Class 3 (excluding trichlorethylene)
 Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04 	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
 Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 	* The supplied plug covers must remain in place over the unused interfaces during operation!
onfiguration / header	
Configuration software	
• STEP 7	Yes; V5.5 or higher
configuration / programming / header	
Command set	see instruction list
Nesting levels	8
System functions (SFC)	see instruction list
System function blocks (SFB)	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
	Yes
 User program protection/password protection 	100
User program protection/password protectionBlock encryption	Yes; With S7 block Privacy
Block encryption	

last modified.	
Weight, approx.	340 g
Weights	
Depth	130 mm

last modified:

5/29/2024 🖸