6AG1512-1SK01-7AB0

SIEMENS

Data sheet



SIPLUS ET 200SP CPU 1512SP F-1 PN based on 6ES7512-1SK01-0AB0 with conformal coating, -40...+70 °C, no pluggable BusAdapter, central processing unit with work memory 300 KB for program and 1 MB for data, 1st interface, PROFINET IRT with 3-port switch, 48 ns bit performance, SIMATIC Memory Card required,

Figure similar

riguresinna	
General information	
Product type designation	CPU 1512SP F-1 PN
based on	6ES7512-1SK01-0AB0
Product function	
	Yes; I&M0 to I&M3
 Module swapping during operation (hot swapping) 	Yes; Multi-hot swapping
Isochronous mode	Yes; Only with PROFINET; with minimum OB $6x$ cycle of $625~\mu s$
Engineering with	
STEP 7 TIA Portal configurable/integrated from version	see entry ID: 109746275
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
Mains/voltage failure stored energy time	5 ms
Input current	
Current consumption (rated value)	0.6 A
Current consumption, max.	0.9 A
Inrush current, max.	4.7 A; Rated value
l²t	0.14 A ² ·s
Power	
Infeed power to the backplane bus	8.75 W
Power loss	
Power loss, typ.	5.6 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
integrated (for program)	300 kbyte
• integrated (for data)	1 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte
Backup	
maintenance-free	Yes

CPU processing times	
for bit operations, typ.	48 ns
for word operations, typ.	58 ns
	77 ns
for fixed point arithmetic, typ. for floating point arithmetic, typ.	307 ns
CPU-blocks	307 118
	A OOO, Disable (OD, ED, EO, DD) and UDT-
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	Timbyto, Tot Doo man account accounty, and main old to the
Number range	0 65 535
• Size, max.	200 kbyte
FC	200 hbyte
Number range	0 65 535
• Size, max.	200 kbyte
OB	200 hbyte
• Size, max.	200 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
	20
Number of delay alarm OBsNumber of cyclic interrupt OBs	20; With minimum OB 3x cycle of 500 µs
•	
Number of process alarm OBs Number of DRV4 clares OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	1
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; Available retentive memory for bit memories, timers, counters, DBs,
	and technology data (axes): 88 KB
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
 per priority class, max. 	64 kbyte; max. 16 KB per block

Address area	
Number of IO modules	2 048; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	288 byte; For input and output data respectively
Address space per station	
Address space per station, max.	2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	,
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	1
Number of IO Controllers	
• integrated	1
• Via CM	0
Rack	
Modules per rack, max.	80; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules; > 60 °C ambient temperature CPU + 32 modules + server module + 16 ET 200AL modules
 Quantity of operable ET 200SP modules, max. 	64; > 60 °C ambient temperature: 32 modules
 Quantity of operable ET 200AL modules, max. 	16
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
• to DP, master	Yes; Via CM DP module
• on DP, device	Yes; Via CM DP module
• in AS, master	Yes
• in AS, device	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	1
Number of PROFIBUS interfaces	1; Via CM DP module
Optical interface	No No
1. Interface	
Interface types	
• RJ 45 (Ethernet)	Yes; X1 P3
Number of ports	1
BusAdapter (PROFINET)	No
Protocols	110
• IP protocol	Yes; IPv4
▼ II protocor	166, II V 4

 PROFINET IO Controller 	Vee
- DDOFINET IO Davisa	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
 Prioritized startup 	Yes; Max. 32 PROFINET devices
 Number of connectable IO Devices, max. 	128; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	$250~\mu s$ to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 μs : 375 μs , 625 μs 3 875 $\mu s)$
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
 PG/OP communication 	Yes
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	Yes; per user program
— Shared device	Yes
 Number of IO Controllers with shared device, max. 	4
 activation/deactivation of I-devices 	Yes; per user program
Asset management record	Yes; per user program
2. Interface	
Interface types	
• RS 485	Yes; Via CM DP module
Number of ports	1
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP device	Yes
SIMATIC communication	Yes
- Onvirtino communication	
PROFIBILS DP master	
PROFIBUS DP master • Number of connections may	48: Of which 4 each reserved for ES and HMI
Number of connections, max. max. number of DP devices	48; Of which 4 each reserved for ES and HMI 125; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET

— PG/OP communication	Yes
— Equidistance	No
— Isochronous mode	No
— activation/deactivation of DP devices	Yes
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
 Autonegotiation 	Yes
 Autocrossing 	Yes
Industrial Ethernet status LED	Yes
RS 485	
 Transmission rate, max. 	12 Mbit/s
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
 Number of connections, max. 	128; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10
 Number of connections via integrated interfaces 	88
 Number of connections per CP/CM 	32
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	No
Media redundancy	
— Media redundancy	No
— MRP	No
 MRP interconnection, supported 	No
— MRPD	No
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
 S7 communication, as client 	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
DHCP	Yes
• DNS	Yes
• SNMP	Yes
• SNWP • DCP	Yes
• LLDP	Yes Ontional
• Encryption	Yes; Optional
Web server	Veg. Standard and user pages
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	Von
Runtime license required ORC LIA Client	Yes
OPC UA Client Application outleastication	Yes
Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of connections, max.	4
 Number of nodes of the client interfaces, 	1 000

recommended max.	
 Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max. 	300
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions for session management, per connection, max. 	1
 Number of simultaneous calls of the client instructions for data access, per connection, max. 	5
 Number of registerable nodes, max. 	5 000
 Number of registerable method calls of OPC_UA_MethodCall, max. 	100
 Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of sessions, max.	32
— Number of accessible variables, max.	50 000
— Number of registerable nodes, max.	10 000
Number of subscriptions per session, max.	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
Number of inputs/outputs per server method, max.	20
Number of impate outputs per server method, max. Number of monitored items, recommended max.	1 000; for 1 s sampling interval and 1 s send interval
Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the
— Number of Server Interfaces, max.	type "Reference namespace"
	31
 Number of nodes for user-defined server interfaces, max. 	1 000
· · · · · · · · · · · · · · · · · · ·	1 000
max.	1 000 Yes; MODBUS TCP
max. Further protocols	
max. Further protocols • MODBUS	
max. Further protocols • MODBUS S7 message functions	Yes; MODBUS TCP
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max.	Yes; MODBUS TCP
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block,
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
max. Further protocols MODBUS To message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
max. Further protocols ■ MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
max. Further protocols ■ MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering)	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems
max. Further protocols MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
max. Further protocols MODBUS Test commission (Team Engineering) Status block Single step	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
max. Further protocols	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
max. Further protocols	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
max. Further protocols MODBUS Test commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variables Variables	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe
max. Further protocols	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
max. Further protocols MODBUS Tessage functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe
max. Further protocols MODBUS Tessage functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing Forcing, variables	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe Peripheral inputs/outputs
max. Further protocols MODBUS Tessage functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing Forcing, variables Number of variables, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe
max. Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe Peripheral inputs/outputs 200
max. Further protocols MODBUS Tessage functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer present	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe Peripheral inputs/outputs 200 Yes
max. Further protocols MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer present Number of entries, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe Peripheral inputs/outputs 200 Yes 1 000
max. Further protocols MODBUS Tessage functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing, variables Number of variables, max. Diagnostic buffer present	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes; without fail-safe Peripheral inputs/outputs 200 Yes

Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
 Monitoring of the supply voltage (PWR-LED) 	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
	program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for technology objects 	800
 Required Motion Control resources 	
 per speed-controlled axis 	40
per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
Number of positioning axes at motion control cycle of 4 ms (typical value)	5
— Number of positioning axes at motion control cycle of 8 ms (typical value)	10
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
• PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	res, r 10 controller with integrated optimization for temperature
High-speed counter	Yes
Standards, approvals, certificates	165
Highest safety class achievable in safety mode	
Performance level according to ISO 13849-1	PLe
SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair time	
Low demand mode: PFDavg in accordance with SIL3	< 2.00E-05
High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient conditions Ambient temperature during operation	
· • • • • • • • • • • • • • • • • • • •	-40 °C; = Tmin (incl. condensation/frost)
horizontal installation, min.	
 horizontal installation, max. 	70 °C; = Tmax
• vertical installation, min	40 °C₁ – Tmin
vertical installation, min. vertical installation, may	-40 °C; = Tmin
• vertical installation, max.	-40 °C; = Tmin 50 °C; = Tmax
vertical installation, max. Altitude during operation relating to sea level	50 °C; = Tmax
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. 	
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068- 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state),
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state),
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants — Resistant to commercially available coolants and lubricants	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state),
vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants — Resistant to commercially available coolants and	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants — Resistant to commercially available coolants and lubricants	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants Resistant to commercially available coolants and lubricants Use in stationary industrial systems to biologically active substances according to EN 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation No Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna);
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants Resistant to commercially available coolants and lubricants Use in stationary industrial systems to biologically active substances according to EN 60721-3-3 to chemically active substances according to EN 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation No Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity
 vertical installation, max. Altitude during operation relating to sea level Installation altitude above sea level, max. Relative humidity With condensation, tested in accordance with IEC 60068-2-38, max. Resistance Coolants and lubricants Resistant to commercially available coolants and lubricants Use in stationary industrial systems to biologically active substances according to EN 60721-3-3 to chemically active substances according to EN 60721-3-3 to mechanically active substances according to EN 	50 °C; = Tmax 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual 100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation No Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *

 to biologically active substances according to EN 60721-3-6 	Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna)
 to chemically active substances according to EN 60721-3-6 	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
 to mechanically active substances according to EN 60721-3-6 	Yes; Class 6S3 incl. sand, dust (with the exception of oil droplets in the air); *
Usage in industrial process technology	
 Against chemically active substances acc. to EN 60654-4 	Yes; Class 3 (excluding trichlorethylene)
 Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04 	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
 Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
 Coatings for printed circuit board assemblies acc. to EN 61086 	Yes; Class 2 for high reliability
 Protection against fouling acc. to EN 60664-3 	Yes; Type 1 protection
 Military testing according to MIL-I-46058C, Amendment 7 	Yes; Discoloration of coating possible during service life
 Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC- CC-830A 	Yes; Conformal coating, Class A
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes; incl. failsafe
— FBD	Yes; incl. failsafe
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
 User program protection/password protection 	Yes
Copy protection	Yes
Block protection	Yes
Access protection	
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Complete protection 	Yes
programming / cycle time monitoring / header	
• lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	470 g

last modified:

7/13/2024