Data sheet



SIPLUS S7-1500 CPU 1518F-4 PN/DP based on 6ES7518-4FP00-0AB0 with conformal coating, 0...+60 °C, central processing unit with work memory 4.5 MB for program and 10 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface, Ethernet, 3rd interface, Ethernet, 4th interface, PROFIBUS, 1 ns bit performance, SIMATIC Memory Card required

General information	
Product type designation	CPU 1518F-4PN/DP
Product function	
● I&M data	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 125 μs (distributed) and 1 ms (central)
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	see entry ID: 109746275
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	6.1 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	1.55 A
Inrush current, max.	2.4 A; Rated value
l²t	0.02 A ² ·s
Power	
Infeed power to the backplane bus	12 W
Power consumption from the backplane bus (balanced)	30 W
Power loss	
Power loss, typ.	24 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
integrated (for program)	9 Mbyte
integrated (for data)	60 Mbyte
Load memory	
 Plug-in (SIMATIC Memory Card), max. 	32 Gbyte

Backup	
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	1 ns
for word operations, typ.	2 ns
for fixed point arithmetic, typ.	2 ns
for floating point arithmetic, typ.	6 ns
CPU-blocks	0115
Number of elements (total)	20 000: Plocks (OP EP EC DP) and UDTs
DB	20 000; Blocks (OB, FB, FC, DB) and UDTs
Number range	1 60 999; subdivided into: number range that can be used by the user: 1
• Number range	59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	16 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	1 Mbyte
FC	
Number range	0 65 535
• Size, max.	1 Mbyte
ОВ	
• Size, max.	1 Mbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
Number of cyclic interrupt OBs	20; with minimum OB 3x cycle of 100 μs
Number of process alarm OBs	50
 Number of DPV1 alarm OBs 	3
 Number of isochronous mode OBs 	3
 Number of technology synchronous alarm OBs 	2
Number of startup OBs	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
 Number of diagnostic alarm OBs 	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	768 kbyte; In total; available retentive memory for bit memories, timers,
	counters, DBs, and technology data (axes): 700 KB
Extended retentive data area (incl. timers, counters, flags), max.	20 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	4011.1
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes

Retentivity preset	No
Local data	
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	or rayto, max. To the por blook
Number of IO modules	16 384; max. number of modules / submodules
I/O address area	10 304, max. number of modules / submodules
• Inputs	32 kbyte; All inputs are in the process image
• Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	32 kbyte, All outputs are in the process image
— Inputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
— Outputs (volume)	32 kbyte; max. 32 KB via X1; max. 8 KB via X2 or X4
per CM/CP	32 kbyte, max. 32 kb via X1, max. 6 kb via X2 or X4
·	8 kbyte
— Inputs (volume)— Outputs (volume)	8 kbyte
	o kdyte
Subprocess images	22
Number of subprocess images, max.	32
Hardware configuration	
Number of distributed IO systems	64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• integrated	1
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be
Number of IO Controllers	inserted in total
Number of IO Controllers	
• integrated	2
• Via CM	8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
Modules per rack, max.	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available
	slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
 Deviation per day, max. 	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
• to DP, master	Yes
• in AS, master	Yes
• in AS, device	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	3
Number of PROFIBUS interfaces	1
1. Interface	
Interface types	
• RJ 45 (Ethernet)	Yes; X1
Number of ports	2
• integrated switch	Yes
Protocols	
IP protocol	Yes; IPv4
- II protocor	
PROFINET IO Controller	Yes
PROFINET IO ControllerPROFINET IO Device	Yes Yes
PROFINET IO ControllerPROFINET IO DeviceSIMATIC communication	Yes Yes Yes
PROFINET IO ControllerPROFINET IO Device	Yes Yes

Media redundancy	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	100, Mill Flatering a doording to 120 of 100 f Edition 2.0
Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
Prioritized startup	Yes; Max. 32 PROFINET devices
Number of connectable IO Devices, max.	512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, max. 	512
— of which in line, max.	512
Number of IO Devices that can be simultaneously activated/deactivated, max.	8; in total across all interfaces
— Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 125 μs	125 µs
— for send cycle of 187.5 μs	187.5 µs
— for send cycle of 250 μs	250 μs to 4 ms
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
— With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 $\mu s: 375~\mu s, 625~\mu s \dots 3~875~\mu s)$
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes; Minimum send cycle of 250 μs
— PROFlenergy	Yes; per user program
— Shared device	Yes
 Number of IO Controllers with shared device, max. 	4
 activation/deactivation of I-devices 	Yes; per user program
Asset management record	Yes; per user program
2. Interface	
Interface types	Voc. VO
RJ 45 (Ethernet) Alumbas of parts	Yes; X2
Number of ports integrated suitable	1 No
integrated switch	No
Protocols	Voc. IDv4
IP protocol PROFINET IO Controller	Yes; IPv4
PROFINET IO Controller PROFINET IO Devices	Yes
PROFINET IO Device SIMATIC communication	Yes
SIMATIC communication One IF communication	Yes Ontionally also anaryted
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	No
PROFINET IO Controller	
Services	V
— PG/OP communication	Yes

— Isochronous mode	No
Direct data exchange	No
— IRT	No
— PROFlenergy	Yes; per user program
Prioritized startup	No
Number of connectable IO Devices, max.	128; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Number of connectable IO Devices for RT, max.	128
— of which in line, max.	128
Number of IO Devices that can be simultaneously	8; in total across all interfaces
activated/deactivated, max.	
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for RT	
— for send cycle of 1 ms	1 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	No
— PROFlenergy	Yes; per user program
— Prioritized startup	No
— Shared device	Yes
Number of IO Controllers with shared device, max.	4
activation/deactivation of I-devices	Yes; per user program
— Asset management record	Yes; per user program
3. Interface	
Interface types	Yes; X3
RJ 45 (Ethernet)Number of ports	1
• integrated switch	No
Protocols	INO
• IP protocol	Yes; IPv4
PROFINET IO Controller	No
PROFINET IO Device	No
SIMATIC communication	Yes
Open IE communication	Yes
Web server	Yes
4. Interface	
Interface types	
• RS 485	Yes; X4
Number of ports	1
Protocols	
 PROFIBUS DP master 	Yes
PROFIBUS DP device	No
SIMATIC communication	Yes
PROFIBUS DP master	
 Number of connections, max. 	48; for the integrated PROFIBUS DP interface
max. number of DP devices	125; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
Services	V
— PG/OP communication	Yes
— Equidistance	Yes
— Isochronous mode	Yes
— activation/deactivation of DP devices	Yes
Interface types	
RJ 45 (Ethernet)	Von
• 100 Mbps	Yes: Only possible at the Y3 interface of the CPLL1518
1000 MbpsAutonegotiation	Yes; Only possible at the X3 interface of the CPU 1518 Yes
- Autoriegotiation	160

a Autopropoing	Voc
Autocrossing Industrial Ethernet status LED	Yes Yes
Industrial Ethernet status LED RS 485	100
Transmission rate, max.	12 Mbit/s
Protocols	12 HIDIO
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
Number of connections, max.	384; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections reserved for ES/HMI/web	10
 Number of connections via integrated interfaces 	320
Number of S7 routing paths	64; in total, only 16 S7-Routing connections are supported via PROFIBUS
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	only via 1st interface (X1)
— MRP	Yes; as MRP redundancy manager and/or MRP client
 MRP interconnection, supported 	Yes; as ring node according to IEC 62439-2 Edition 2.0
— MRPD	Yes; Requirement: IRT
 Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
 Number of stations in the ring, max. 	50
SIMATIC communication	
• S7 routing	Yes
Data record routing	Yes
• S7 communication, as server	Yes
 S7 communication, as client 	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
 several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; 128 multicast circuits (of which max. 5 via X1)
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes
OPC UA Client	Yes
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of connections, max.	40
 Number of nodes of the client interfaces, recommended max. 	5 000
 Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max. 	300
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions for session management, per connection, 	1

max.	
Number of simultaneous calls of the client	5
instructions for data access, per connection, max.	
 Number of registerable nodes, max. 	5 000
Number of registerable method calls of	100
OPC_UA_MethodCall, max.	20
 Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
— Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
— Number of sessions, max.	64
Number of accessible variables, max.	200 000
Number of registerable nodes, max.	50 000
Number of subscriptions per session, max.	20
— Sampling interval, min.	10 ms
— Publishing interval, min.	10 ms
Number of server methods, max.	100
Number of inputs/outputs per server method, max. Number of manifered items, recommended may.	20
Number of server interfaces, max.	10 000; for 1 s sampling interval and 1 s send interval
Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 Number of nodes for user-defined server interfaces, max. 	30 000
Alarms and Conditions	
Number of program alarms	400
Number of alarms for system diagnostics	200
Further protocols	
• MODBUS	Yes; MODBUS TCP
Isochronous mode	
Equidistance	Yes
Lyuiuistanice	
S7 message functions	
4	64
S7 message functions Number of login stations for message functions, max. Program alarms	
S7 message functions Number of login stations for message functions, max.	64
S7 message functions Number of login stations for message functions, max. Program alarms	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block,
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects	64 Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients)
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients)
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max.	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max.	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job
S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. Forcing Forcing	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing Forcing, variables	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. Forcing Forcing Forcing Forcing Forcing, variables, max. Number of variables, max.	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe)
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. Forcing • Forcing • Forcing • Forcing, variables, max. Diagnostic buffer	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200
Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing • Forcing • Forcing • Forcing, variables • Number of variables, max. Diagnostic buffer • present	Yes 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 5 000 4 000 1 000 480 Yes; Parallel online access possible for up to 10 engineering systems Yes; Up to 16 simultaneously (in total across all ES clients) No 20 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job Yes; without fail-safe peripheral inputs/outputs (without fail-safe) 200 Yes; without fail-safe

Traces	
Number of configurable Traces	8; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
 Connection display LINK TX/RX 	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of the PLC
Number of available Motion Control resources for tachas law a bioate.	program; selection guide via the TIA Selection Tool 15 360
technology objects	
Required Motion Control resources Per speed controlled axis	40
per speed-controlled axis per positioning axis	80
	160
— per synchronous axis	
— per external encoder	80 20
— per output cam	
— per cam track	160
— per probe	40
Positioning axis	440
Number of positioning axes at motion control cycle of 4 ms (typical value)	140
 Number of positioning axes at motion control cycle of 8 ms (typical value) 	192
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
 Performance level according to ISO 13849-1 	PLe
SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair time	e of 100 hours)
 Low demand mode: PFDavg in accordance with SIL3 	< 2.00E-05
 High demand/continuous mode: PFH in accordance with SIL3 	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
 horizontal installation, min. 	0 °C
• horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
 vertical installation, min. 	0 °C
vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
Installation altitude above sea level, max.	5 000 m
Ambient air temperature-barometric pressure-altitude	Restrictions for installation altitudes > 2 000 m, see entry ID: 109763260
Relative humidity	
With condensation, tested in accordance with IEC 60068- 2-38, max.	100 %; RH incl. condensation/frost (no commissioning under condensation conditions)
Resistance	
Coolants and lubricants	
 Resistant to commercially available coolants and lubricants 	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	

Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); - to biologically active substances according to EN 60721-3-3 Class 3B3 on request - to chemically active substances according to EN Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); — to mechanically active substances according to EN Yes; Class 3S4 incl. sand, dust, * 60721-3-3 Use on ships/at sea to biologically active substances according to EN Yes; Class 6B2 mold and fungal spores (excluding fauna); Class 6B3 on 60721-3-6 - to chemically active substances according to EN Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity 60721-3-6 degree 3); - to mechanically active substances according to EN Yes; Class 6S3 incl. sand, dust; * 60721-3-6 Usage in industrial process technology - Against chemically active substances acc. to EN Yes; Class 3 (excluding trichlorethylene) 60654-4 - Environmental conditions for process, measuring Yes; Level GX group A/B (excluding trichlorethylene; harmful gas and control systems acc. to ANSI/ISA-71.04 concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil) Remark - Note regarding classification of environmental The supplied plug covers must remain in place over the unused interfaces conditions acc. to EN 60721, EN 60654-4 and during operation! ANSI/ISA-71.04 Conformal coating Yes; Class 2 for high reliability . Coatings for printed circuit board assemblies acc. to EN • Protection against fouling acc. to EN 60664-3 Yes; Type 1 protection • Military testing according to MIL-I-46058C, Amendment 7 Yes; Discoloration of coating possible during service life Qualification and Performance of Electrical Insulating Yes; Conformal coating, Class A Compound for Printed Board Assemblies according to IPC-CC-830A configuration / header configuration / programming / header Programming language - LAD Yes; incl. failsafe — FBD Yes: incl. failsafe — STL Yes - SCI Yes - GRAPH Yes Know-how protection • User program protection/password protection Yes Copy protection Yes Block protection Yes Access protection • Password for display Yes Protection level: Write protection Yes; Specific write protection both for Standard and for Failsafe • Protection level: Read/write protection Yes • Protection level: Write protection for Failsafe Yes • Protection level: Complete protection Yes programming / cycle time monitoring / header • lower limit adjustable minimum cycle time • upper limit adjustable maximum cycle time Dimensions Width 175 mm Height 147 mm Depth 129 mm **Veights** 1 988 g Weight, approx.

Page 9/9

6AG15184FP004AB0

last modified:

7/13/2024