SIEMENS

Data sheet

6AG2243-5DX30-1XE0

product type designation



SIPLUS S7-1200 CM 1243-5 RAIL

SIPLUS S7-1200 CM 1243-5 T1 rail based on 6GK7243-5DX30-0XE0 with conformal coating, -25...+55 °C, OT1 with ST1/2 (+70 °C für 10 minutes), communications module CM 1243-5 for connecting S7-1200 to PROFIBUS as DP master module

Figure similar

transfer rate	
transfer rate	
 at the 1st interface / according to PROFIBUS 	9.6 kbit/s 12 Mbit/s
interfaces	
number of interfaces / according to Industrial Ethernet	0
number of electrical connections	
 at the 1st interface / according to PROFIBUS 	1
 for power supply 	1
type of electrical connection	
 at the 1st interface / according to PROFIBUS 	9-pin Sub-D socket (RS485)
 for power supply 	3-pole terminal block
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage / external	24 V
supply voltage / external / at DC / rated value	24 V
relative positive tolerance / at DC / at 24 V	20 %
relative negative tolerance / at DC / at 24 V	20 %
consumed current	
 from external supply voltage / at DC / at 24 V / typical 	0.1 A
power loss [W]	2.4 W
ambient conditions	
ambient temperature	
 during operation 	-25 +55 °C
during storage	-40 +70 °C
 during transport 	-40 +70 °C
note	+70 °C for 10 min (OT1, ST1/ST2 according to EN 50155)
installation altitude / at height above sea level / maximum	2000 m
ambient condition / relating to ambient temperature - air pressure - installation altitude	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m)
relative humidity	
 with condensation / according to IEC 60068-2-38 / maximum 	100 %; RH including condensation/frost (no commissioning when condensation is present), horizontal installation
chemical resistance / to commercially available cooling lubricants	Yes; incl. airborne diesel and oil droplets
resistance to biologically active substances	
• conformity according to EN 60721-3-3	Yes; Class 3B2 mold and fungal spores (excluding fauna), Class 3B3 on request
• conformity according to EN 60721-3-5	Yes; Class 5B2 mold and fungal spores (excluding fauna), Class 5B3 on request
resistance to chemically active substances	

 conformity according to EN 60721-3-3 	Yes; Class 3C4 (RH < 75 %) incl. salt spray in accordance with EN 60068-2-52 (Severity 3). The supplied plug covers must remain in place on the unused interfaces during operation.
• conformity according to EN 60721-3-5	Yes; Class 5C3 (RH < 75%) including salt spray acc. to EN 60068-2-52 (Severity level 3). The supplied plug covers must remain in place over the unused interfaces during operation!
· · · · · · · · · · · · · · · · · · ·	
 resistance to mechanically active substances conformity according to EN 60721-3-3 	Yes; Class 3S4 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation.
• conformity according to EN 60721-3-5	Yes; Class 5S3 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation!
coating / for equipped printed circuit board / according to EN 61086	Yes; Class 2 for high availability
type of coating / protection against pollution according to EN 60664-3	Yes; Protection of the type 1
type of coating / for electronic devices in railway applications according to EN 50155	Yes; Protective coating of the Class PC2 according to EN 50155:2018
type of test / of the coating / according to MIL-I-46058C	Yes; Coating discoloration during service life possible
product conformity / of the coating / Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A	Yes; Conformal coating, class A
protection class IP	IP20
design, dimensions and weights	
module format	Compact module S7-1200 single width
width	30 mm
height	100 mm
·	75 mm
depth	
net weight	0.134 kg
fastening method	
 35 mm top hat DIN rail mounting 	Yes
 S7-300 rail mounting 	No
wall mounting	Yes
product features, product functions, product components / gene	eral
number of units	
 per CPU / maximum 	1
performance data / PROFIBUS DP	
service / as DP master	
• DPV1	Yes
number of DP slaves	
 on DP master / operable 	16
data volume	
 of the address range of the inputs / as DP master / total 	512 byte
 of the address range of the outputs / as DP master / total 	512 byte
 of the address range of the inputs / per DP slave 	244 byte
 of the address range of the outputs / per DP slave 	244 byte
 of the address range of the diagnostic data / per DP slave 	240 byte
service / as DP slave	
• DPV0	No
• DPV1	No
• DFVT performance data / S7 communication	
number of possible connections / for S7 communication	0: may 4 connections to other 07 statistic
maximum	8; max. 4 connections to other S7 stations
with PG connections / maximum	1
 with PG/OP connections / maximum 	3
performance data / multi-protocol mode	
number of active connections / with multi-protocol mode	
without DP / maximum	8
with DP / maximum	8
performance data / telecontrol	
protocol / is supported	
• TCP/IP	No
product functions / management, configuration, engineering	
configuration software	
required	#NO DATA

product functions / position detection	
certificate of suitability / railway application in accordance with	Yes; EMC for railway vehicles
EN 50121-3-2 certificate of suitability / railway application in accordance with	Yes; EMC for signal and telecommunication equipment
EN 50121-4 certificate of suitability / railway application in accordance with	Yes; Railway applications - Overvoltage category OV2 pollution degree PD2
EN 50124-1 certificate of suitability / railway application in accordance with	rated impulse voltage UNi = 0.5 kVUNm = DC 24 Yes; Railway vehicles - See ambient conditions
EN 50125-1	
certificate of suitability / railway application in accordance with EN 50125-2	Yes; Fixed-electrical installations - see ambient conditions
certificate of suitability / railway application in accordance with EN 50125-3	Yes; Signal and telecommunications equipment - see Ambient conditions vibrations and shocks: Application point outside the rails (distance 1 m to 3 m from rail)
certificate of suitability / railway application in accordance with EN 50155	Yes; Railway vehicles - temperature class OT1, ST1/ST2, horizontal mounting position
certificate of suitability / railway application in accordance with EN 61373	Yes; Railway vehicles - Vibrations and shocks Category 1 Class A/B
certificate of suitability / fire protection in accordance with EN 45545-2	Yes; Railway vehicles - for proof, see Service & Support
tandards, specifications, approvals	
reference code	
according to IEC 81346-2:2019	KEC
urther information / internet links	
internet link	
 to web page: selection aid TIA Selection Tool 	https://www.siemens.com/tstcloud
• to website: Industrial communication	https://www.siemens.com/simatic-net
• to web page: SiePortal	https://sieportal.siemens.com/
• to website: Image database	https://www.automation.siemens.com/bilddb
• to website: CAx-Download-Manager	https://www.siemens.com/cax
to website: Industry Online Support	https://support.industry.siemens.com
ecurity information	
	In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongl recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)
Approvals / Certificates	
General Product Approval	EMV
Miscellaneous CEC Manufacturer tion	
Railway	
Confirmation	
last modified:	8/22/2024 🖸